

# IAPMO RESEARCH AND TESTING, INC.

5001 East Philadelphia Street, Ontario, California 91761-2816 – USA • 909-472-4100 • 909-472-4244 • www.iapmort.org



## CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

Effective Date: January 2019

Void After: January 2024

Product: Drinking Water Treatment Units - Aesthetic Effects

File No. WP-10372

Issued To: Pelican Water Systems  
3060 Performance Circle Ste. 2  
Deland, FL 32724

Identification: Each product shall be permanently and legibly marked by means of a permanent plate(s) or label(s) affixed in a readily accessible location to the system. This information shall include the model number, name and address of manufacturer, functional description of the system, maximum working pressure in kPa (psig), maximum operating temperature in degrees C (degrees F), and a statement noting that the system conforms to NSF/ANSI 42 for the specific performance claims as verified and substantiated by test data.

Where applicable and appropriate, the information shall also include the model number of replacement components, electrical requirements, and a statement (or its equivalence) for activated carbon systems: "Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system."

Characteristics: Materials or products that come into contact with drinking water and/or drinking water treatment chemicals.

  
Chairman, Product Certification Committee

  
CEO, The IAPMO Group

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.





# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

Void After: January 2024

Product: Drinking Water Treatment Units - Aesthetic Effects

File No. WP-10372

Issued To: Pelican Water Systems

Certification demonstrates that all materials safety and structural integrity (as applicable) requirements have been met.

Products and materials may include process media, protective materials, joining and sealing materials, pipes and related products, mechanical devices used with treatment/transmission/distribution systems, and mechanical plumbing devices. To be installed in accordance with the manufacturer's instructions.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following standard(s):

NSF/ANSI 42-2017



# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

*This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)*

Void After: January 2024

Product: Drinking Water Treatment Units - Aesthetic Effects

File No. WP-10372

Issued To: Pelican Water Systems

MODELS:

| <u>Model Number</u> | <u>Flow Rate (GPM)</u> | <u>Capacity (Gallons)</u> | <u>Replacement Component</u>             | <u>Reduction Claims</u>          |
|---------------------|------------------------|---------------------------|--|----------------------------------|
| PDF-1000VF          | 0.5                    | 1000                      | PDF-VF-RO1,<br>PDF-VF-RO2,<br>PDF-VF-RO3 | Chlorine, Particulate<br>Class I |